

SRS Project Options



Moore + Bruggink Consulting Engineers

Creating Community Since 1956





SRS Project Options

Background

- Project Goals
- Capture a revenue stream that is currently leaving the Township
- Eliminate septage land application which can potentially be harmful to the lakes
- Wastewater Lagoon Basis of Design
- Hydraulic Capacity Fluid Volume
- Organic Loading Stuff needing treatment
- MDEQ Discussions concerning septage land-app elimination

of septage in the Twp or the Co, but in order for the ordinance to be ordinance septage generated within the Twp or Co, and get DEO approval of the enforceable, [They] would have to have the capacity to take all the Part 117 allows for Twp or Co ordinances to have supremacy. [The Township] can write an ordinance that would prohibit land application

1/29/2019

SRS Project Options

Two Potential Projects

- Build a smaller SRS without creating an Ordinance.
- Lower capital costs
- Captures revenue
- Doesn't eliminate land application of septage around the lakes
- 2. Build a larger SRS and create an Ordinance
- Higher capital costs
- Higher revenue capture
- Eliminates land application of septage around the lakes

1/29/2019 SRS Project Options

Aeration Technologies to meet organic loading




Aire-O,® Aspirator Aerator











Project 1

Aeration Technologies Cost Analysis - Original Plan

Total HP	20-yr System Cost \$ 5,115	* 45 45 N N	20-yr Maintena	44	en.									0-yr Energy Cost	**	44	40	6/1	44	40	69 1	60	Syatem Coat
j	oot 115,942.06	2,542,781,25 2,542,781,25 254,278,12 2,797,059,37	ince and Re	1,419,120.00	0.10	14 191 200	365	1944	0.75	2592	0.0	24	5 72	OS.	899,762.69	117,380,35	782,402.34	130,400.39	103,666.99	30,000.00	86,389,16	431 945 90	
	9m Coef \$ 5,115,942.06 20-yr OM&R	Design Life in years Full system replacements Only year Replacement costs General maintenance (10%) Total M&R Cost	r Maintenance and Replacement Cost	20-year Energy Cost	SAWh	kWh/20 years			(kWh)/(HP-h/d)			Hrs/d	2 units 5 HP/Unit		System Cost	Engineering Cost	Total Capital Cost	Contingency (20%)	Electrical (20%)			Capital Coefe	
3		985				-		Option to the last of the last															

\$ 3,369,269.81 20-yr OM&R	20-yr System Cost	10 Design Life in years 2.00 Full system replacements \$ 1,207,054.08 20-year Replacement cos \$ 120,705.41 General maintenance (10 \$ 1,327,759.49 Total M&R Cost	20-yr Maintenance and Replacement Cost	\$ 0.10 \$/kWh \$ 1,596,510.00 20-year Energy Cost	15,985,100 kWh/20 years	0.75 (kWh)/(HP-hd)	2916 BHP-IVd	18 units 7.5 HP/Unit	20-yr Energy Coat	\$ 445,000.32 System Cost	58,043.52	\$ 386,956.80 Total Canital Cost	48,744.00	\$ 203,100.00 Capital Costs \$ 40,620.00 Installation Costs (20%)	stem Cost	Inage Aerators
		Design Life in years Full system replacements 20-year Replacement costs General maintenance (10%) Total M&R Cost		gy Cost		٥	idency				Cost	(94m2)	8)	osts (20%)		

20-yr Syatem Coat	er in in	20-yr Mainte	40-40						20-yr Energ		2.0					Syatem Coal	Carle later and income
am Coat	20 1.00 887.063.23 88.706.32 976,429.56	ir Maintenance and Replacement Cost	1,773,90	17 730 000	N	_ 0	,		y Cost	636,489.22	87,791.62	548,697,60	71,208.00	\$ 30,000,00	\$ 59,340.00		C STYLE ISSUED
	20 Desig 100 Full s 123 20-ye 132 Gene 136 Total	Replacen		100		0.75 RWhur		24 High									
	Design Life in years Full system replacements 20-year Replacement costs General maintenance (10%) Total M&R Cost	territ Cost	SkWh 20-year Energy Cost	years years	۵	BHP-Md BHP-Md	Operating Efficiency			System Cost	Engineering Cost	Total Capital Cost	Electrical (20%)	work	Capital Costs Installation Costs (20%)		
	lacement lacement ement co nance (1)		y Cost				iency				ost	Ost (48/D)	•		sts (20%)		
	96) 354 (4																

Total HP

150

Total HP

Project 2

Aeration Technologies Cost Analysis - Full Township

2.00 Full system replacements \$ 2,542,781.25 20-year Replacement costs \$ 254,278.12 General maintenance (10%) \$ 2,797,059.37 Total M&R Cost 20-yr System Cost	2,00 2,542,781.25 254,278.12 2,797,059.37	10 Design Life in years	20-yr Maintenance and Replacement Cost	15 units 15 units 10 HP/Unit 24 Hrs/d 0.9 Operating Efficiency 3240 BHP-h/d 0.75 (kMh)/HP-h/d) 2430 kWh-d 365 dly 20 years 17,739,000 kWh/20 years \$ 1,773,900.00 20-year Energy Cost	20-yr Energy Cost	\$ 899,762.69 System Cost	782,402.34	103,666.99	431,945.80 86,389.16		Aeration Industries
--	--	-------------------------	--	--	-------------------	---------------------------	------------	------------	-------------------------	--	---------------------

\$ 1,404,629,76 20- \$ 140,4629,76 20- \$ 140,46298 Ge \$ 1,545,092,74 To 20-yr System Cost \$ 3,831,259,78 20-		System Cost \$ 236,950.00 Ca \$ 47,390.00 In \$ 30,000.00 St \$ 56,886.00 Ek \$ 56,886.00 Ek \$ 56,886.00 To \$ 445,449.60 To \$ 66,817.44 En \$ 512,267.04 Sy
rull system replacements 20-year Replacement costs General maintenance (10%) Total M&R Cost 20-yr OM&R	HPZUnit Hrs/d Operating Efficiency BHP-tr/d (RWh)/(HP-h/d) kWh-d dy years \$RWh 20-year Energy Cost Design I fo in years	Capital Costs Installation Costs (20%) Sitework Electrical (20%) Contingency (20%) Total Capital Cost Engineering Cost Engineering Cost System Cost

Subsurface Aerators System Cost \$ 445,050.00 Capital Costs \$ 89,010.00 Installation Costs (20%) \$ 30,000.00 Sitework \$ 108,812.00 Electrical (20%) \$ 134,174.40 Contingency (20%) \$ 138,0742 Engineering Cost \$ 933,853.82 System Cost \$ 933,853.82 System Cost \$ 933,853.82 System Cost 2 units 75 HP 24 Hrsid 0.9 Operating Efficiency 3240 BHP-h/d 0.9 Operating Efficiency 3240 BHP-h/d 365 dV 20 years 17,739,000 KWh/dD years \$ 1,773,900.00 Zhyear Energy Cost \$ 1,773,900.00 Zhyear Energy Cost \$ 1,773,900.00 Zhyear Energy Cost \$ 1,2573.48 So-year Replacement costs \$ 1,325,73.48 General maintenance (10%) \$ 1,458,308.33 Total M&R Cost

Septage Air Treatment Project 1: FRP Tank, Existing Pump, 10,000 Gal of

Packaged Station, 10,000 Gal of Septage Treatment Project 1 (Alternate): FRP Tank, Suction Lift

25,000 Gal of Septage Treatment Project 2: Full Township Septage Treatment -

\$675,200

\$766,000

\$980,000

Conclusion

- The only option meeting all the goals is Project 2 Need to average about 5,500 gallons per day (20 day/month) to cover the payments on a 20 year loan at 3.125% (\$66,630/yr.)
- Taking in septage creates the potential for odors
- Recommend discussions of ordinance with an attorney

Jeff S. Landers, P.E.
Project Engineer

jlanders@mbce.com

(616) 363-9801

Questions

